

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

CLIENT DETAILS DJ MATT JACKSON - 5 ELLIS CLOSE - RM16 3DN

CERTIFICATE No. MJE20180901-009

TEST EQUIPMENT	Seaward	Calibration Date	30-Sep-18	Test Engineer M Jackson
Model	PrimeTest 100	Next Calibration Due	30-Sep-19	
Serial No.	29C-0145			

MJ ENTS. ID	SERIAL No.	Description	Class*	Fuse Fitted (A)	Cable Rating (A)	Visual	Earth Continuity (RPE Ω)	Insulation Resistance (Riso MΩ)	Leakage Current (Ileak mA)	Polarity	Function Test	Pass / Fail	Test Date	Next Test Due
Cables														
PCON1		Flight Case Power	NA	5	13	OK	0.06	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
PCON2		13A IEC Cable	NA	13	13	OK	0.09	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
PCON3		13A IEC Cable	NA	13	13	OK	0.04	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
IEC1		13A IEC Cable	NA	13	13	OK	0.08	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
IEC2		13A IEC Cable	NA	13	13	OK	0.08	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
IEC3		13A IEC Cable	NA	13	13	OK	0.08	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
IEC4		13A IEC Cable	NA	13	13	OK	0.05	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
Bel8way		8 way surgemaster	NA	13	13	OK	0.06	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
13A2way01		Custom 3m power extension	NA	13	13	OK	0.13	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
13A2way02		Custom 3m power extension	NA	13	13	OK	0.11	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
DJ Equipment														
CDJ2000A	IJMP001723YY	Pioneer CDJ2000 CD player	2	NA	NA	OK	0.1	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
CDJ2000B	IKMP002693	Pioneer CDJ200 CD Player	2	NA	NA	OK	0.1	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
DJM900nexus		Pioneer DJM900 Audio Mixer	2	NA	NA	OK	0.1	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
DJM700A	IIMP002624YY	Pioneer DJM700 Audio Mixer	2	NA	NA	OK	0.1	19.99	NA	OK	OK	PASS	01/09/2018	01/09/2019
Active Speakers														
RCF HD12a01		RCF 12" Active Speaker	1	NA	NA	OK	0.07	19.99	0.69	OK	OK	PASS	01/09/2018	01/09/2019
RCF HD12a02		RCF 12" Active Speaker	1	NA	NA	OK	0.07	19.99	0.76	OK	OK	PASS	01/09/2018	01/09/2019
Lighting														
Intimidator 300	BR01	Light Effect	1	13	13	OK	0.07	19.99	0.12	OK	OK	PASS	01/09/2018	01/09/2019
Intimidator 300	BR02	Light Effect	1	13	13	OK	0.09	19.99	0.15	OK	OK	PASS	01/09/2018	01/09/2019
Slimpar1	3030404	uplighter	1	NA	NA	OK	0.06	19.99	0.16	OK	OK	PASS	01/09/2018	01/09/2019
Slimpar2	3030404	uplighter	1	NA	NA	OK	0.08	19.99	0.15	OK	OK	PASS	01/09/2018	01/09/2019

*Class I - Single insulated wiring, which requires an earth connection. There is no symbol for a Class I product so if a rating plate has no symbol on it then it is usually Class I.

*Class II - Double insulated wiring, therefore no need for a earth lead + ILeak test results are not applicable . Class II is indicated by double box symbol.

As part of the booking agreement the venue shall provide a minimum of two off 13A 230V outlets with RCD or RCBO protection to at least 17th edition IEE Regulations.